



RFI #1 | Bonneville Drive Properties Office Building

RFI on doors:

- 1. Door type B on A-1 appears to show a large glass insert. Is this correct for all "B" door types?**

No. The Door type B is a Flush HC Steel Door

- 2. Hardware set B appears to be the same as hardware set A. Is this correct?**

Hardware B is incorrect in the plans please use the following

Hardware:

LOCK SET
1 1/2 PAIR BUTT HINGES
SILENCERS (3 PER FRAME MIN)
DOOR STOP. FLOOR MOUNTED